

Cement Test Certificate

Lot 242 Russell Road East, Munster WA 6166 PO Box 38, Hamilton Hill WA 6963 T: +61 8 9411 1000 F: +61 8 9411 1150

Final

Product Certified: Type GP General Purpose Cement Type GP General Purpose Cement

Test Certificate Number: 200253

Despatched From: Cockburn Cement, Port Hedland Plant, WA

 Sample Code:
 B078b80

 Sample Date:
 4/06/2020

| Nominal Blend | Requirements | Result |
|---|--------------|---------|
| Clinker | | >86.5 % |
| Ground Granulated Iron Blast-Furnace Slag | | Nil |
| Mineral Addition | Max 7.5 % | <7.5 % |
| Calcium Sulphate | | <5 % |
| Minor Additional Constituents | Max 5 % | Nil |

| Reportable Property | Tost Mothod | Requirements of | Result |
|---|-------------|-----------------|-----------|
| | Test Method | AS3972 | |
| 3 Day Strength | AS2350.11 | N/R | 36.8 MPa |
| 7 Day Strength | AS2350.11 | Min 35.0 MPa | 46.2 MPa |
| 28 Day Strength | AS2350.11 | Min 45.0 MPa | 61.7 MPa |
| Initial Set Time | AS2350.4 | Min 45 min | 105 min |
| Final Set Time | AS2350.4 | Max 360 min | 165 min |
| Soundness | AS2350.5 | Max 5 mm | 0 mm |
| Sulfuric Anhydride content (SO ₃) | AS2350.2 | Max 3.5 % | 2.7 % |
| Chloride Ion | BH-TM-0507 | Max 0.10 % | 0.012 % |
| Other Properties | | | |
| SiO ₂ | AS2350.2 | N/R | 20.2 % |
| Al_2O_3 | AS2350.2 | N/R | 4.7 % |
| Fe_2O_3 | AS2350.2 | N/R | 3.0 % |
| CaO | AS2350.2 | N/R | 64.5 % |
| MgO | AS2350.2 | N/R | 1.3 % |
| Na₂O Equivalent | AS2350.2 | N/R | 0.5 % |
| Loss on Ignition | AS2350.2 | N/R | 3.2 % |
| Fineness Index | AS2350.8 | N/R | 350 m²/kg |
| Normal Consistency | AS2350.3 | N/R | 26.8 % |

 ${\it This\ document\ shall\ not\ be\ reproduced\ except\ in\ full.}$

REMARKS

These test result apply specifically to the sample as received at the Adelaide Brighton Cement Birkenhead Laboratory (Accreditation number: 252), 62 Elder Rd Birkenhead SA 5015.

This despatch grab sample complies to the requirements of AS3972:2010, Type GP Cement. N/R = No Requirement



Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Approved Signatory

M. Wythe

Issue Date: 14/07/2020